



**S. Todd Stolp, M.D.**  
County Health Officer

## Tuolumne County Health Department

**Environmental Health**  
2 South Green St.  
Sonora, CA 95370  
(209) 533-5990  
Fax: (209) 533-5994

**Brenda Faw**  
Director of  
Environmental  
Health

*Food*  
*Hazardous Materials/*  
*Land Use*  
*Housing*  
*Medical Waste*  
*Public Swimming*  
*Pools*  
*Public Water*  
*Sewage Treatment*  
*and Disposal*  
*Solid Waste*  
*Vector*  
*Water Wells*

**Public Health**  
20111 Cedar Rd. N.  
Sonora, CA 95370  
(209) 533-7400  
Fax: (209) 533-7406

**Kathy Amos**  
Director of  
Public Health  
Nursing

*AIDS Surveillance*  
*California Children's*  
*Services*  
*CHDP*  
*Clinical Services*  
*Communicable*  
*Disease*  
*Emergency Medical*  
*Services*  
*HIV Education and*  
*Prevention*  
*Immunization*  
*Maternal Child*  
*Health*  
*PHN Case*  
*Management*  
*Tobacco Control*  
*WIC*

March 30, 2007

Blue Mountain Minerals  
Carey Haughy, President  
P.O. Box 430  
Columbia, CA 95310-0430

**Subject: Aggregates from Blue Mountain Mineral for use in Septic Systems**

Dear Ms. Haughy,


This Division has received the report from Condor Earth Technologies with the testing results and a recommendation for the use of aggregates from Blue Mountain Minerals for on-site sewage disposal system drainrock.

According to the March 28, 2007 report provided by Condor Earth Technologies; "the result of the testing indicates the drainrock is durable and stable within the pH range associated with septic system effluent. The drainrock should be durable and maintain its primary function, supporting the pipe, trench sidewalls, and overlying soil backfill, for the anticipated 20 to 30 year life of an on-site system."

Based on the report and recommendation provided by Condor Earth Technologies; this Division approves the use of drainrock derived from the Blue Mountain Minerals quarry for use in on-site sewage disposal systems. The Blue Mountain Minerals aggregates will be placed on the product approved list maintained by this Division.

Thank you for providing the documentation necessary for this Division to determine that drainrock from Blue Mountain Minerals is durable and stable for on-site sewage disposal systems.

Respectfully,

  
Brenda Faw, Director  
Environmental Health Division